PRINTED: 06/22/2009 FORM APPROVED Bureau of Health Care Quality & Compliance STATEMENT OF DEFICIENCIES (X1) PROVIDER/SUPPLIER/CLIA (X3) DATE SURVEY (X2) MULTIPLE CONSTRUCTION AND PLAN OF CORRECTION COMPLETED IDENTIFICATION NUMBER: A. BUILDING B. WING NVN240AGC 11/14/2008 STREET ADDRESS, CITY, STATE, ZIP CODE NAME OF PROVIDER OR SUPPLIER 1895 CARVILLE DR **JOHNSON GROUP CARE #1 RENO. NV 89512** SUMMARY STATEMENT OF DEFICIENCIES PROVIDER'S PLAN OF CORRECTION (X4) ID ID (X5) COMPLETE (EACH DEFICIENCY MUST BE PRECEDED BY FULL (EACH CORRECTIVE ACTION SHOULD BE **PREFIX PREFIX** DATE REGULATORY OR LSC IDENTIFYING INFORMATION) CROSS-REFERENCED TO THE APPROPRIATE TAG TAG DEFICIENCY) Y 000 Y 000 **Initial Comments** This Statement of Deficiencies was generated as a result of an annual State Licensure survey conducted in your facility on 11/14/08. This State Licensure survey was conducted by the authority of NRS 449.150, Powers of the Health Division. The facility is licensed for six Residential Facility for Group beds for elderly and disabled persons and/or persons with mental illness, Category I residents. The census at the time of the survey was three. Three resident files were reviewed and two employee files were reviewed. One discharged resident file was reviewed. The findings and conclusions of any investigation by the Health Division shall not be construed as prohibiting any criminal or civil investigations. actions or other claims for relief that may be available to any party under applicable federal, state, or local laws. Y 434 Y 434 449.229(3) Emergency Drills SS=A NAC 449.229 3. A drill for evacuation must be performed monthly on an irregular schedule, and a written record of each drill must be kept on file at the facility for not less than 12 months after the drill.

If deficiencies are cited, an approved plan of correction must be returned within 10 days after receipt of this statement of deficiencies.

TITLE

(X6) DATE

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

December of 2007).

This Regulation is not met as evidenced by: Based on record review on 11/14/08, the facility did not ensure that monthly evacuation drills were conducted for 2 of 12 months (November and

PRINTED: 06/22/2009 FORM APPROVED Bureau of Health Care Quality & Compliance STATEMENT OF DEFICIENCIES (X1) PROVIDER/SUPPLIER/CLIA (X3) DATE SURVEY (X2) MULTIPLE CONSTRUCTION AND PLAN OF CORRECTION COMPLETED IDENTIFICATION NUMBER: A. BUILDING B. WING NVN240AGC 11/14/2008 STREET ADDRESS, CITY, STATE, ZIP CODE NAME OF PROVIDER OR SUPPLIER 1895 CARVILLE DR **JOHNSON GROUP CARE #1 RENO, NV 89512** SUMMARY STATEMENT OF DEFICIENCIES PROVIDER'S PLAN OF CORRECTION (X4) ID ID (X5) (EACH DEFICIENCY MUST BE PRECEDED BY FULL (EACH CORRECTIVE ACTION SHOULD BE COMPLETE PREFIX **PREFIX** DATE REGULATORY OR LSC IDENTIFYING INFORMATION) CROSS-REFERENCED TO THE APPROPRIATE TAG TAG DEFICIENCY) Y 434 Continued From page 1 Y 434 Severity: 1 Scope: 1 Y 444 449.229(9) Smoke Detectors Y 444 SS=A NAC 449.229 9. Smoke detectors must be maintained in proper operating conditions at all times and must be tested monthly. The results of the tests pursuant to this subsection must be recorded and maintained at the facility. This Regulation is not met as evidenced by: Based on record review on 11/14/08, the facility did not ensure smoke detectors were tested 2 out of the past 12 months (November and December 2007). Severity: 1 Scope: 1